

CUSTOM SERIES

OUTSWING WOOD DOORS

FLORIDA STATE APPROVAL

CODE VERSION: FLORIDA BUILDING CODE 2023 - 8th EDITION

APPROVED FOR USE INSIDE HVHZ AND OUTSIDE HVHZ

CATEGORY: EXTERIOR DOORS -- SUBCATEGORY: SWINGING EXTERIOR DOOR ASSEMBLY

IMPACT RESISTANT: LARGE MISSILE


GENERAL NOTES:

- 1- CODE: THIS PRODUCT HAS BEEN TESTED UNDER PROTOCOLS TAS 201, 202 AND 203 AND DESIGNED IN ACCORDANCE WITH THE FBC 2023 - 8th EDITION INCLUDING THE HIGH VELOCITY HURRICANE ZONE (HVHZ).
- 2- DEFINITION: THIS PRODUCT IS AN EXTERIOR OUT SWING WOOD TYPE DOOR DESIGNED, CONSTRUCTED AND TESTED TO PROVIDE PROTECTION FROM HURRICANE FORCE WINDS AND WIND BORNE DEBRIS (LARGE & SMALL MISSILE) WITHIN THE ALLOWABLE DESIGNED PRESSURES AND LIMITATIONS STATED IN THIS APPROVAL.
- 3- POSTING: PRODUCT SHALL BE LABELED AS PER FBC SECTION 1703.5. THE PERMANENT LABEL, MARKING OR ETCHING SHALL PROVIDE TRACEABILITY TO THE MANUFACTURER AND PRODUCT.
- 4- LOADS: DESIGNED LOAD CALCULATED BASED ON THE ASCE 7-22 AND PROVIDED BY A PROFESSIONAL ARCHITECT OR ENGINEER FOR EACH SPECIFIC PROJECT. THE CALCULATED DESIGNED PRESSURE MUST NOT EXCEED THE ALLOWABLE PRESSURES HERE IN SPECIFIED. THE ULTIMATE DESIGN PRESSURES, AS DETERMINED FROM ASCE 7-22, ARE PERMITTED TO BE MULTIPLIED BY 0.6 AS PER THE FLORIDA BUILDING CODE.
- 5- MATERIAL:
- 5.1- ALL WOOD TO BE WITH MINIMUM 0.55 SPECIFIC GRAVITY CORRECTED FOR 12% MOISTURE CONTENT PER NDS 0.58 RAW. DENSITY OF BUTCHER BLOCK CONSTRUCTION WITH VENEER 0.535 g/cm ^ 3.
- 5.2- GLAZING: LAMINATED IMPACTED RATED AS SPECIFIED IN THIS APPROVAL
- 6- FASTENERS: ASSEMBLY SCREWS AND ANCHORS SHALL BE AS SPECIFIED IN THE CURRENT SET OF DRAWINGS.
- 7- USE: IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR, ARCHITECT OR ENGINEER OF RECORD TO VERIFY THE FOLLOWING:
- 7.1- THE STABILITY OF THE STRUCTURE WHERE THE PRODUCT IS TO BE ATTACHED INSURING PROPER ANCHORAGE.
- 7.2- THE SITE SPECIFIC PROJECT CRITERIA, SUCH AS BUT NOT LIMITED TO, LOCAL CODE REQUIREMENTS, DESIGNED PRESSURES ETC.
- 7.3- THAT THIS APPROVAL IS ADEQUATE TO THE SPECIFIC PROJECT.

TABLE OF CONTENTS:


SHEET	DESCRIPTION
1 OF 16	GENERAL NOTES, TABLE OF CONTENTS, TESTED UNITS
2 OF 16	MODEL 1 ELEVATIONS
3 OF 16	MODEL 2 ELEVATIONS
4 OF 16	MODEL 3 ELEVATIONS
5 OF 16	MODEL 4 ELEVATIONS
6 OF 16	MODEL 6 ELEVATIONS
7 OF 16	MODELS 1, 2, 3, 4 AND 6 SECTIONS
8 OF 16	MODEL 3 AND 6 SECTIONS
9 OF 16	MODELS 1, 2, 3 AND 4 GLAZING DETAILS AND BILL OF MATERIALS
10 OF 16	MODEL 6 GLAZING DETAILS AND BILL OF MATERIALS
11 OF 16	MODELS 1, 2, 3, 4 AND 6 COMPONENTS
12 OF 16	MODEL 5 ELEVATIONS
13 OF 16	MODELS 5 SECTIONS, BILL OF MATERIALS AND COMPONENTS
14 OF 16	FRAMING ANCHORAGE
15 OF 16	QUALIFIED PANELS AND FRAMING CONFIGURATIONS
16 OF 16	SASH & FRAME ASSEMBLY

TESTED UNITS



MODEL 1

MODEL 2



MODEL 4

MODEL 5

Pedro Figueiredo

Digitally signed by Pedro Figueiredo

Date: 2023.10.19 07:18:32 -04'00'


DIGITALLY SIGNED FOR 16 PAGES

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO, PE 52609 ON THE DATE INDICATED HERE.




Pedro De Figueiredo
10/19/2023

ENGINEERING SERVICES - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PTMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609



MODEL 3

WIND STRUCTURAL: PD= +65 PSF, -65 PSF
WIND CYCLIC: PD= +65 PSF, -65 PSF
IMPACT RATING: LARGE & SMALL MISSILE
OPERATING FORCE
WATER RESISTANCE: ASTM E331, 11.25 PSF (15% OF +75 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588



MODEL 6

WIND STRUCTURAL: PD= +65 ** PSF, -65 PSF
WIND CYCLIC: PD= +65 PSF, -65 PSF
IMPACT RATING: LARGE & SMALL MISSILE

** PRODUCT POSITIVE PRESSURE TO BE LIMITED TO +60 PSF FOR INSTALLATIONS WITHOUT AN OVERHANG MEETING THE OH ratio= OH length/ OH height
DOOR COVERAGE (FBC SECTION 1709.5.1)


OPERATING FORCE
WATER RESISTANCE: ASTM E331
9 PSF -- (15% OF +60 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588

PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED


MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
1 OF 16


MODEL I




EXTERIOR SIDE ELEVATION
RECTANGULAR TYPE PAIR DOOR XX



SEE SHEET 14 TO SELECT ANCHOR OPTIONS



LOCK HARDWARE:



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
2 OF 16

MODEL I
RECTANGULAR SWING-OUT
PAIR DOOR XX: (MAX. 74 1/2" X 121 9/16")
SINGLE DOOR X: (MAX. 38 3/8" X 121 9/16")


PD= +65 PSF, -65 PSF

OPERATING FORCE
WATER RESISTANCE: ASTM E331, 11.25 PSF
(15% OF +75 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588


HARDWARE NOTES:

- 1- SURFACE BOLTS: (4) SURFACE BOLTS BY CUSTOM PART #H-3 WERE INSTALLED IN THE ACTIVE AND INACTIVE LEAVES AT TOP AND BOTTOM.
THE BOTTOM SURFACE BOLTS WERE ATTACHED USING LOCK GUIDES FROM THE EDGE OF THE ASTRAGAL AT: 3 7/8", 5/8" AND 6 5/8" USING (2) #8X1 1/2" SS PFH SMS PER LOCATION.
THE TOP SURFACE BOLTS WERE ATTACHED USING LOCK GUIDES FROM THE TOP EDGE OF THE ASTRAGAL AT: 3 7/8", 5/8", 9" AND 18 1/2" USING (2) #8 X 1 1/2" SS PFH SMS PER LOCATION. A LOCK BAR REINF. GUIDE WAS INSTALLED USING (2) #1 2X3 SS PFH SMS.
- 2- STRIKE PLATES:
2.1- FRAME HEAD & SILL: A 1 1/8X2X1 1/4 GA THICK SS STRIKE PLATE WERE INSTALLED ON THE HEADER AND SILL USING (4) #1 2X3 SS PFH SMS. THE STRIKE PLATES WERE FLUSH WITH THE SURFACE OF THE SILL AND HEADER.
2.2- INACTIVE SASH: (3) STRIKE PLATES WERE INSTALLED IN THE INACTIVE LEAF AT CORRESPONDING POSITIONS AND WERE ATTACHED USING (4,3,4) #10X3 SS PFH SMS STARTING FROM BOTTOM OF THE LEAF
- 3- DOOR HANDLE: A DUMMY HANDLE WAS INSTALLED ON THE INACTIVE LEAF.
- 4- ACTIVE DOOR LOCK: A (3) POINT WITH AN ADDITIONAL LATCHING POINT, CUSTOM # H1 WAS INSTALLED IN THE ACTIVE DOOR LEAF AT 42" FROM THE BOTTOM OF THE ACTIVE DOOR LEAF. THE LOCKING POINTS WERE AT 13.5, 40.5, 43.375, 68.75 FROM THE BOTTOM OF THE ACTIVE LEAF. THE LOCK WAS INSTALLED USING (9) #10X2 SS PFH SMS AT 10" AND 9" OC AVERAGE FROM THE BOTTOM OF THE DOOR LEAF.
- 5- HINGES: (4) 4.5X4.5 SOLID BRASS HINGES BY CUSTOM PART# H-2 WERE ATTACHED TO THE DOOR FRAME AND DOOR LEAVES USING (2) #1 2X3 / (2) #1 2X 1 1/4 PFH SMS AND WERE ATTACHED TO THE DOOR LEAF USING (4) #1 2X3 PFH SMS.

MODEL 2



EXTERIOR SIDE ELEVATION
ARCHED TYPE PAIR DOOR XX



SEE SHEET 14 TO SELECT ANCHOR OPTIONS

CUSTOM 4 POINT
LOCK INSTALLED TO
THE ACTIVE STILE W/
(13) #10X2 PFH SMS
AT AVG 8" OC

LOCK HARDWARE:

H4 W/ 1/2" DIAMX2" LONG
SHEAR PIN W/ 3/4" THROW.
11GA SS REINF. PLATE W/ A
GUIDE SHEAR ROD. THE PLATE
WERE GLUE AND ATTACHED W/
(3) #12X3 SS PFH SMS AND
(4) #10X 1 1/2" SS PFH SMS

STRIKE PLATE SECURED
TO INACTIVE STILE
W/ (4) #10X2 PFH SMS


STRIKE PLATE SECURED
TO INACTIVE STILE
W/ (4) #10X2 PFH SMS

STRIKE PLATE SECURED
TO INACTIVE STILE
W/ (3) #10X2 PFH SMS

DUMMY HANDLE

STRIKE PLATE SECURED
TO INACTIVE STILE
W/ (4) #10X3 PFH SMS

H4 W/ 1/2" DIAMX2" LONG
SHEAR PIN W/ 3/4" THROW.
11GA SS REINF. PLATE W/ A
GUIDE SHEAR ROD. THE PLATE
WERE GLUE AND ATTACHED W/
(3) #12X3 SS PFH SMS AND
(4) #10X 1 1/2" SS PFH SMS



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.

PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:

NA

DATE:

10/19/2023

DRAWING #

23-202

SHEET

3 OF 16


MODEL 2
RECTANGULAR SWING-OUT
PAIR DOOR XX: (MAX. 74 1/2" X 122 3/4")
SINGLE DOOR X: (MAX. 38 3/8" X 122 3/4")

PD= +65 PSF, -65 PSF

OPERATING FORCE
WATER RESISTANCE: ASTM E331, 11.25 PSF
(15% OF +75 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588

HARDWARE NOTES:

- 1- FLUSH BOLTS: THE INACTIVE DOOR LEAF CONTAINED A CONCEALED FLUSH BOLT CUSTOM PART # H4 WITH 1/2" DIAMX2" LONG SHEAR PIN WITH 3/4" THROW AT TOP AND BOTTOM. THE LOCK CONTAINED AN 11GA SS REINFORCEMENT PLATE WITH A GUIDE SHEAR ROD AT TOP & BOTTOM. THE REINF. PLATE WERE GLUE USING ASHALAND ISOGRIP SP 3030 D AND WERE ATTACHED USING (3) #12X3 SS PFH SMS FROM BOTTOM AND (4) #10X 1 1/2" SS PFH SMS FROM INTERIOR EDGE.
- 2- STRIKE PLATES:
 - 2.1- FRAME HEAD & SILL: a 1X2X0.244 THICK SS STRIKE PLATE WERE INSTALLED ON THE HEADER AND SILL USING (4) #12X3 SS PFH SMS. THE STRIKE PLATES WERE FLUSH WITH THE SURFACE OF THE SILL AND HEADER.
 - 2.2- INACTIVE SASH: (4) 0.8X6.9" LONG STRIKE PLATE WERE INSTALLED IN THE INACTIVE LEAF EACH USING (4) #10X2 PFH SMS. THE STRIKE PLATE WERE INSTALLED TO MATCH THE LOCK POINTS FROM THE BOTTOM OF THE LEAF. THE SECOND STRIKE PLATE HAS TWO CUT-OUTS
- 3- DOOR HANDLE: A DUMMY HANDLE WAS INSTALLED ON THE INACTIVE LEAF.
- 4- ACTIVE DOOR LOCK: A (4) POINT WITH AN ADDITIONAL LATCHING POINT, CUSTOM # H1A WAS INSTALLED IN THE ACTIVE DOOR LEAF AT 42" FROM THE BOTTOM OF THE ACTIVE DOOR LEAF. THE LOCKING POINTS WERE AS INDICATED IN THE ILLUSTRATION ABOVE FROM THE BOTTOM OF THE ACTIVE LEAF. THE LOCK WAS INSTALLED USING (13) #10X2 SS PFH SMS AT 9 3/8" FROM THE BOTTOM OF THE DOOR AND 8" OC AVERAGE.
- 5- HINGES: (4) 4.5X4.5 SOLID BRASS HINGES BY CUSTOM PART# H-2 WERE ATTACHED TO THE DOOR FRAME AND DOOR LEAVES USING (4) #12X3 PFH SMS AND WERE ATTACHED TO THE DOOR LEAF USING (4) #12X3 PFH SMS.



EXTERIOR SIDE ELEVATION
RECTANGULAR PAIR DOOR
O-XX-O WITH SIDELITES

MODEL 3

RECTANGULAR SWING-OUT W/ SIDELITES
PAIR DOOR XX: (MAX. 74 5/8" X 122 1/2")
SINGLE DOOR X: (MAX. 38 7/16" X 122 1/2")
SIDELITE O: (MAX. 45" X 122 1/2")


PD= +65 PSF, -65 PSF

OPERATING FORCE
WATER RESISTANCE: ASTM E331, 11.25 PSF
(15% OF +75 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588

SASH CONSTRUCTION:

THE DOOR LEAF CORNERS AND INTERMEDIATE CONNECTIONS WERE RABBET BUTT JOINED USING MORTISE AND TENON CONNECTIONS.
BOTTOM RAIL TO VERTICAL STILE: 6 3/4 X 3/4 X 1 7/8" TENON INTO THE STILE
TOP RAIL TO VERTICAL STILE: 4 1/4 X 3/4 X 1 7/8" LONG TENON INTO THE STILE
INTERMEDIATE RAIL TO VERTICAL STILE: 4 1/4 X 3/4 X 1 7/8" LONG TENON INTO THE STILE
INTERMEDIATE RAIL TO HORIZONTAL RAILS: 4 1/4 X 3/4 X 1 7/8" LONG TENON INTO RAILS
THE ASTRAGAL WAS ATTACHED TO THE DOOR SASH USING (11) #8X1 WOOD SCREWS AT 11"OC.

MODEL 3




SEE SHEET 14 TO SELECT ANCHOR OPTIONS

LOCK HARDWARE:
SAME AS SHEET 3

HARDWARE NOTES:

- 1- FLUSH BOLTS: THE INACTIVE DOOR LEAF CONTAINED A CONCEALED FLUSH BOLT CUSTOM PART # H4 WITH 1/2" DIAM X2" LONG SHEAR PIN WITH 3/4" THROW AT TOP AND BOTTOM. THE LOCK CONTAINED AN 11 GA SS REINFORCEMENT PLATE WITH A GUIDE SHEAR ROD AT TOP & BOTTOM. THE REINFORCING PLATE WERE ATTACHED USING (3) #12X3 SS PFH SMS FROM BOTTOM AND (4) #10X1 1/2" SS PFH SMS FROM INTERIOR EDGE. THE FLUSH BOLTS WERE 2 5/8" FROM THE VERTICAL END OF THE LOCK STILE.
- 2- STRIKE PLATES:
 - 2.1- FRAME HEAD & SILL: A 1 1/2X3X1/4 THICK STEEL STRIKE PLATES WERE INSTALLED ON THE HEADER AND SILL USING (4) #12X3 PFH SMS. THE STRIKE PLATES WERE FLUSH WITH THE SURFACE OF THE SILL AND HEADER.
 - 2.2- INACTIVE SASH: (4) 0.8X6.9" LONG STRIKE PLATE WERE INSTALLED IN THE INACTIVE LEAF EACH USING (4) #10X2 PFH SMS, EXCEPT 2ND FROM THE BOTTOM WITH (3) SCREWS SAME TYPE. THE STRIKE PLATE WERE INSTALLED TO MATCH THE LOCK POINTS FROM THE BOTTOM OF THE LEAF. THE SECOND STRIKE PLATE HAS TWO CUT-OUTS
- 3- DOOR HANDLE: A DUMMY HANDLE WAS INSTALLED ON THE INACTIVE LEAF.
- 4- ACTIVE DOOR LOCK: A (4) POINT WITH AN ADDITIONAL LATCHING POINT, CUSTOM # H1A WAS INSTALLED IN THE ACTIVE DOOR LEAF AT 42" FROM THE BOTTOM OF THE ACTIVE DOOR LEAF. THE LOCKING POINTS WERE AS INDICATED IN THE ILLUSTRATION AS PER SHEET 3 OF 14 FROM THE BOTTOM OF THE ACTIVE LEAF. THE LOCK WAS INSTALLED USING (15) #10X2 SS PFH SMS AT 8 3/4" FROM THE BOTTOM OF THE DOOR AND 7 7/8" OC AVERAGE.
- 5- HINGES: (5) 4.5X4.5 SOLID BRASS HINGES BY CUSTOM PART# H-2 WERE ATTACHED TO THE DOOR FRAME AND DOOR LEAVES USING (4) #12X3 PFH SMS AND WERE ATTACHED TO THE DOOR LEAF USING (4) #12X3 PFH SMS.



Pedro De Figueiredo
10/19/2023



THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.

PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED



MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
4 OF 16

MODEL 4



SEE SHEET 14 TO SELECT ANCHOR OPTIONS



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
5 OF 16

ENGINEER: PEDRO M. DE FIGUEIREDO
PE 52609
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609

MODEL 4
RECTANGULAR SWING-OUT 1 3/4"
SINGLE DOOR X: (MAX. 50 1/2" X 122 1/2")
PD= +65 PSF, -65 PSF

OPERATING FORCE
WATER RESISTANCE: ASTM E331, 11.25 PSF
(15% OF +75 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588

HARDWARE NOTES:

- 1- DOOR HANDLE: ACTIVATING THE LATCH WAS INSTALLED AT 42" FROM THE BOTTOM OF THE DOOR.
- 2- ACTIVE DOOR LOCK: A (5) POINT LOCKING MECHANISM WITH AN ADDITIONAL LATCH, # H1A - 5 POINT BY CUSTOM, WAS INSTALLED ON THE LEAF. EACH POINT LOCK PROTRUDED 1 3/16". THE CORRESPONDING (5) 6 7/8" X 0.80 X 0.112" PAINTED STEEL STRIKES PLATES WITH 1.73" X 0.50" SLOT WERE ATTACHED TO THE DOOR JAMB AS ILLUSTRATED ABOVE
- 3- HINGES: (5) 4.5X4.5 SOLID BRASS HINGES BY CUSTOM PART# H-2 WERE ATTACHED TO THE DOOR FRAME AND DOOR LEAVES USING (4) #12X3 PFH SMS AND WERE ATTACHED TO THE DOOR LEAF USING (4) #12X3 PFH SMS.

[illegible]

MODEL 6 RECTANGULAR W/ TRANSOM SWING-OUT PAIR DOOR XX-O: (MAX. 74 1/2" X 160 3/8") SINGLE DOOR X-O: (MAX. 38 3/8" X 160 3/8")
PD= +65 PSF, -65 PSF

Diagram illustrating the reinforcement layout for a wall section, showing anchors and spacing details:

- Top and Bottom Edges:** Anchors at 13" OC (On Center).
- Left and Right Edges:** Anchors spaced at maximum 12" OC.
- Reinforcement:** 1/4-20X3 SS PFH MS W/ NUT SPACED AT 12 1/4" OC.
- Clustering:**
 - CLUSTER OF 5 ANCHORS AT 4" OC (indicated by a cloud shape).
 - CLUSTER OF 3 ANCHORS AT 3" OC (indicated by a cloud shape).
- Dimensions:**
 - Overall width: 47/8
 - Overall height: 65/8

CLUSTER OF
(4) ANCHORS
AT 4" OC

Technical drawing of a door lock hardware assembly, showing two views: a side view (left) and a front view (right).

Side View (Left): Shows the door panel with a handle (H4) and a lock mechanism. The handle is labeled H4. The lock mechanism is shown in a side profile. A dimension line indicates the distance from the handle to the lock mechanism.

Front View (Right): Shows the lock mechanism with dimensions: 12, 29 1/2, 25 1/2, 25, and 12. A note indicates "CUSTOMER LOCK THE A W/ C AT A".

A circular professional engineer seal for Pedro M. de Figueiredo. The outer ring contains the text "PEDRO M. DE FIGUEIREDO" at the top and "PROFESSIONAL ENGINEER" at the bottom, separated by two stars. Inside the ring, the word "LICENSE" is at the top, "No. 52609" is in the center, and "STATE OF FLORIDA" is at the bottom, also separated by two stars. The seal has a decorative dotted border.

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.








MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SHEET
6 OF 16

- 1- FLUSH BOLTS: CUSTOM PART H-24 INSTALLED IN THE INACTIVE LEAF 1'7 1/4" FROM THE TOP AND 1'9 1/2" FROM THE BOTTOM OF THE SASH. THE LOCK CONTAINED AN 1 1/2" GA SS REINFORCEMENT PLATE WITH A GUIDE SHEAR ROD AT TOP AND BOTTOM. THE REINF. PLATE WERE GLUED USING ASHLAND ISOGRIP SP 3030D AND WERE ATTACHED USING (3) #12X3 SS PFH SMS FROM BOTTOM AND (4) #10X1 1/2" SS PFH SMS FROM THE INTERIOR EDGE.
- 2- STRIKE PLATES:
 - 2.1- FRAME HEAD & SILL: A 1X2X0.244 THICK SS STRIKE PLATE WERE INSTALLED ON THE HEADER AND SILL USING (4) #12X3 SS PFH SMS. THE STRIKE PLATES WERE FLUSH WITH THE SURFACE OF THE SILL AND HEADER.
 - 2.2- INACTIVE SASH: (4) 0.8X6.9" LONG STRIKE PLATES WERE INSTALLED IN THE INACTIVE LEAF USING (4) #12 X 1 1/2" PFH SMS.
- 3- DOOR HANDLE: A DUMMY HANDLE WAS INSTALLED ON THE INACTIVE LEAF.
- 4- ACTIVE DOOR LOCK: A (4) POINT WITH AN ADDITIONAL LATCHING POINT, CUSTOM # H1A WAS INSTALLED IN THE ACTIVE DOOR LEAF AT 42" FROM THE BOTTOM OF THE ACTIVE DOOR LEAF. THE LOCKING POINTS WERE AT 12, 41.5, 67 AND 92 FROM THE BOTTOM OF THE ACTIVE LEAF. THE LOCK WAS INSTALLED USING (13) #10X2 SS PFH SMS AT 9.375", 16.375, 25.25, 34.5, 46.375, 55.5, 64.5, 71.25, 78.75, 80.875, 90, 96.75, 105 FROM THE BOTTOM OF THE DOOR LEAF.
- 5- HINGES: (5) 4.5X4.5 SOLID BRASS HINGES BY CUSTOM PART# H-2 WERE ATTACHED TO THE DOOR FRAME AND DOOR LEAVES USING (4) #12X3 PFH SMS.

MODELS 1, 2, 3, 4 AND 6 - SECTIONS



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.

ENGINEER
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PTMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609








PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI-FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
7 OF 16

MODELS 3 AND 6 - SECTIONS



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.




PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220



SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
8 OF 16

MODELS 1, 2, 3 AND 4 - BILL OF MATERIALS & GLAZING DETAILS


GLAZING DETAILS



GLASS GLAZING METHOD:
GLASS AND GLAZING STOP WERE WET GLAZED
USING DOW 995 SILICONE AND FURTHER
ATTACHED USING #8X2 PFH SMS.



WOOD PANEL GLAZING METHOD:
PANEL AND GLAZING STOP WERE WET GLAZED
USING DOW 995 SILICONE AND FURTHER
ATTACHED USING #8X2 PFH SMS.



BILL OF MATERIALS:

PART#	DESCRIPTION	MATERIAL
1	6 5/8 X 1 3/4 HEADER/ JAMB	LAMINATED WOOD
2	6 5/8 X 1 3/4 SILL	SOLID WOOD
3	7 X 2 1/4 HINGE STILE	BUTCHED BLOCK W/ VENEER
4	7 X 2 1/4 LOCK STILE	BUTCHED BLOCK W/ VENEER
5	7 X 2 1/4 TOP RAIL	BUTCHED BLOCK W/ VENEER
6	9 3/8 X 2 1/4 BOTTOM RAIL	BUTCHED BLOCK W/ VENEER
7	7 X 2 1/4 INTERMEDIATE RAIL	BUTCHED BLOCK W/ VENEER
8	3/4 X 3/16 INSIDE MOULDING	SOLID WOOD
9	1 1/4 X 1 1/8 GLAZING STOP	SOLID WOOD
10	1 1/2 X 5/8 INACTIVE ASTRAGAL	SOLID WOOD
11	1 3/4 X 1 1/4 ACTIVE ASTRAGAL	LAMINATED WOOD
12	2 1/4" LAMINATED WD PANEL	LAMINATED WOOD
13	1/2" IMPACT GLASS	LAMINATED ANNEAL GLASS
14	DOW CORNING 995	STRUCTURAL SILICONE
15	1.22X.51 WEAR STRIP	ALUMINUM
16	1 1/2 X 3/4 DRIP CAP	SOLID WOOD
16.1	2.3X3 TRANSOM SASH	BUTCHED BLOCK W/ VENEER

ASSEMBLY SCREWS & NAILS:


PART#	DESCRIPTION	MATERIAL
S1	#10 X 3" PFH SMS	ZINC PLATED STEEL
S2	#6 X 1 1/4" PFH SMS	ZINC PLATED STEEL
S3	18 GA X 1" BRAD NAIL	GALVANIZED STEEL
S4	#6 X 1 1/2" PFH SMS	ZINC PLATED STEEL
S5	#8 X 2" PFH SMS	ZINC PLATED STEEL
S6	#12 X 1 1/4" PFH SMS	ZINC PLATED STEEL
S7	#12 X 3" PFH SMS	ZINC PLATED STEEL
S8	#8 X 1 1/2" PFH SMS	ZINC PLATED STEEL
S9	#10 X 2" PFH SMS	ZINC PLATED STEEL

DOOR HARDWARE:

PART#	DESCRIPTION	MATERIAL
H1	CUSTOM 4 POINT LOCK	STEEL
H2	4.5X4.5 CUSTOM HINGES	SOLID BRASS
H3	CUSTOM SURFACE BOLTS	STEEL
H4	1 1/8"X2"X1 1/2 GA STRIKE PLATE	STAINLESS STEEL

DOOR WEATHER STRIPPING:

PART#	DESCRIPTION	MATERIAL
W1	QEBD 650 KERF	BY SCHLEGEL
W2	BULB VINYL	NEOPRENE
W3	QE2D 320 FLAT	BY SCHLEGEL



Pedro De Figueiredo
10/19/2023



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED


MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
9 OF 16

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.


MODELS 6 - BILL OF MATERIALS & GLAZING DETAILS

GLAZING DETAILS




GLASS GLAZING METHOD:
GLASS AND GLAZING STOP WERE WET GLAZED
USING DOW 995 SILICONE AND FURTHER
ATTACHED USING #8X2 PFH SMS.


GLAZING DESIGN COMPLIANT W/ ASTM E1300




WOOD PANEL GLAZING METHOD:
PANEL AND GLAZING STOP WERE WET GLAZED
USING DOW 995 SILICONE AND FURTHER
ATTACHED USING #8X2 PFH SMS.



TRANSOM GLAZING



DOOR GLAZING



DOOR WOOD
PANEL

BILL OF MATERIALS:

PART#	DESCRIPTION	MATERIAL
1	6 5/8 X 1 3/4 HEADER/ JAMB	LAMINATED WOOD
2	6 5/8 X 1 3/4 SILL	SOLID WOOD
3	7 X 2 1/4 HINGE STILE	BUTCHED BLOCK W/ VENEER
4	7 X 2 1/4 LOCK STILE	BUTCHED BLOCK W/ VENEER
5	7 X 2 1/4 TOP RAIL	BUTCHED BLOCK W/ VENEER
6	9 3/8 X 2 1/4 BOTTOM RAIL	BUTCHED BLOCK W/ VENEER
7	7 X 2 1/4 INTERMEDIATE RAIL	BUTCHED BLOCK W/ VENEER
8	3/4 X 3/1 6 INSIDE MOULDING	SOLID WOOD
9	1 1/4 X 1 1/8 GLAZING STOP	SOLID WOOD
10	1 1/2 X 5/8 INACTIVE ASTRAGAL	SOLID WOOD
11	1 3/4 X 1 1/4 ACTIVE ASTRAGAL	LAMINATED WOOD
12	2 1/4" LAMINATED WD PANEL	LAMINATED WOOD
13	1/2" IMPACT GLASS	LAMINATED ANNEAL GLASS
14	DOW CORNING 995	STRUCTURAL SILICONE
15	1.22X.51 WEAR STRIP	ALUMINUM
16	1 1/2 X 3/4 DRIP CAP	SOLID WOOD
16.1	2.3X3 TRANSOM SASH	BUTCHED BLOCK W/ VENEER

ASSEMBLY SCREWS & NAILS:


PART#	DESCRIPTION	MATERIAL
S1	#10 X 3" PFH SMS	ZINC PLATED STEEL
S2	#6 X 1 1/4" PFH SMS	ZINC PLATED STEEL
S3	18 GA X 1" BRAD NAIL	GALVANIZED STEEL
S4	#6 X 1 1/2" PFH SMS	ZINC PLATED STEEL
S5	#8 X 2" PFH SMS	ZINC PLATED STEEL
S6	#12 X 1 1/4" PFH SMS	ZINC PLATED STEEL
S7	#12 X 3" PFH SMS	ZINC PLATED STEEL
S8	#8 X 1 1/2" PFH SMS	ZINC PLATED STEEL
S9	#10 X 2" PFH SMS	ZINC PLATED STEEL

DOOR HARDWARE:

PART#	DESCRIPTION	MATERIAL
H1	CUSTOM 4 POINT LOCK	STEEL
H2	4.5X4.5 CUSTOM HINGES	SOLID BRASS
H3	CUSTOM SURFACE BOLTS	STEEL
H4	1 1/8"X2"X1 1 GA STRIKE PLATE	STAINLESS STEEL

DOOR WEATHER STRIPPING:

PART#	DESCRIPTION	MATERIAL
W1	QEBD 650 KERF	BY SCHLEGEL
W2	BULB VINYL	NEOPRENE
W3	QE2D 320 FLAT	BY SCHLEGEL



Pedro De Figueiredo
10/19/2023















THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.

PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
10 OF 16

MODELS 1, 2, 3, 4 AND 6 - COMPONENTS



Pedro De Figueiredo
10/19/2023



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220


SCALE:
NA

DATE:
10/19/2023


DRAWING #
23-202

SHEET
11 OF 16

MODEL 5




EXTERIOR SIDE ELEVATION
RECTANGULAR TYPE SINGLE DOOR X
BUTCHER BLOCK ONE SLAB CONSTRUCTION



SEE SHEET 14 TO SELECT ANCHOR OPTIONS

4 POINT LOCK MODEL 5000 BY VACHETTE INSTALLED TO THE ACTIVE LEAF. THE MAIN LOCK WAS LOCATED AT 37 7/8" FROM THE BOTTOM. LOCK WAS SECURED BY (15) #6X2 PFH SMS SPACED AT 8" OC AVERAGE.



HARDWARE NOTES:

- 1- DOOR LOCK: A (4) POINT LOCKING MECHANISM MODEL 5000 BY VACHETTE, WAS INSTALLED ON THE LEAF. EACH POINT LOCK PROTRUDED 1 3/16" AND WERE LOCATED AS PER ILLUSTRATION ABOVE. THE MAIN LATCH WAS LOCATED AT 37 7/8" FROM THE BOTTOM OF THE LEAF. THE FOUR POINT LOCK ASSEMBLY WAS ATTACHED TO THE LEAF USING (15) #6X2 PFH SMS 1 1/2" FROM THE BOTTOM AND 7 5/8" OC AVERAGE.
- 2- STRIKE PLATES: THE STRIKE PLATES WERE INSTALLED AT THE LOCATIONS CORRESPONDING TO THE LOCK POINTS. EACH STRIKE PLATE WAS ATTACHED TO THE FRAME JAMB USING (4) #10X2" PFH SMS EXCEPT THE STRIKE PLATE CORRESPONDING TO THE LATCH LOCK OR 2ND POINT FROM THE BOTTOM WHICH ONLY USED (3) #10X2" PFH SMS.
- 3- HINGES: (4) PIVOTA DX 300 3-D CP SAFE HINGES BY BASYS WERE ATTACHED TO THE DOOR LEAF AS PER ELEVATION. THE HINGES WERE SECURED TO THE DOOR JAMBS WITH (4) SCREWS ((2) #12X1 1/2" PFH SMS AND (2) 1/4 X 3 1/4") AND SECURED TO THE LEAF WITH (4) 1/4X2 1/2" PFH SMS.
- 4- REINFORCEMENT: (6) 5/8" DIAMETER X 33 3/4" LONG STEEL RODS LOCATED AS PER ELEVATION INSTALLED IN THE BUTCHER BLOCK CONSTRUCTED AREA.

MODEL 4
RECTANGULAR BUTCHER BLOCK SLAB SWING-OUT
SINGLE DOOR X: (MAX. 45 1/2" X 121 3/4")
PD= +65 PSF, -65 PSF

OPERATING FORCE
WATER RESISTANCE: ASTM E331, 11.25 PSF
(15% OF +75 PSF)
AIR INFILTRATION: ASTM E283
FORCE ENTRY: ASTM F588

A1

A2

A3


A4

ALTERNATE DOOR PANELS

NOTES:

1- ILLUSTRATED ABOVE IS JUST FOR A FEW VARIATIONS OF MANY POSSIBLE COMBINATIONS.

2- COMBINATIONS OF ALTERNATE DOOR PANELS ARE ACCEPTABLE IF DESIGN ARE MADE WITH SURFACE APPLIED MOLDING OVER THE MAIN 2-1/4" BUTCHER BLOCK SLAB OR VENEER GROOVING.



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.




PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
12 OF 16

ENGINEER: PEDRO M. DE FIGUEIREDO - CA 32459
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PFMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609

MODEL 5 - SECTIONS, BILL OF MATERIALS AND COMPONENTS



BILL OF MATERIALS:

PART#	DESCRIPTION	MATERIAL
1	6 5/8 X 1 3/4 HEADER/ JAMB	LAMINATED WOOD
2	6 5/8 X 1 3/4 SILL	SOLID WOOD
12.1	2 1/4" BUTCHER BLOCK PANEL	BUTCHER BLOCK WOOD
15	1.22 X .51 WEAR STRIP	ALUMINUM

ASSEMBLY SCREWS & NAILS:



PART#	DESCRIPTION	MATERIAL
S1	#10 X 3" PFH SMS	ZINC PLATED STEEL
S9	#10 X 2" PFH SMS	ZINC PLATED STEEL
S10	#12 X 1 1/2" PFH SMS	ZINC PLATED STEEL
S11	1/4" X 3 1/4" PFH SMS	ZINC PLATED STEEL
S12	1/4" X 2 1/2" PFH SMS	ZINC PLATED STEEL
S13	#6 X 2" PFH SMS	ZINC PLATED STEEL

DOOR HARDWARE:

PART#	DESCRIPTION	MATERIAL
H11	MODEL 5000 BY VACHETTE	STEEL
H21	PIVOTA DX 300 3-D CP HINGES	BY BASYS

DOOR WEATHER STRIPPING:

PART#	DESCRIPTION	MATERIAL
W1	QEBD 650 KERF	BY SCHLEGEL
W3	QEZD 320 FLAT	BY SCHLEGEL



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED


MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA


DATE:
10/19/2023

DRAWING #
23-202



SHEET
13 OF 16




12.1 - DOOR PANEL W/OUT RAILS/ STILES
WOOD PANEL CONSTRUCTION
CENTER 1 3/8" BUTCHED BLOCK
EXTERIOR/ INTERIOR MAHOGANY VENEER



TYPICAL HORIZONTAL
1/8" X 3/16" GROOVE
(6) 5/8 DIAM X 33 3/4"
STEEL REINFORCEMENT ROD
INSIDE PANEL STARTING AT 17"
FROM THE BOTTOM AND SPACED
AT MAXIMUM 17" OC



MODELS 1, 2, 3, 4, 5 AND 6 - FRAMING ANCHORAGE



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED


MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
14 OF 16


FRAMING ANCHORAGE DETAILS			
OPTION 1 FRAME MOUNTED DIRECTLY INTO SUBSTRATE WITH MAXIMUM 1/4" SHIM AND 1/4" ULTRACONS BY ELCO WITH 1 3/4" MIN. EMBEDMENT INTO GROUT FILLED MASONRY (JAMBS) OR INTO 3000 PSI CONCRETE (REFER TO ELEVATIONS FOR ANCHORS QTY. AND LAY-OUT)	OPTION 2 FRAME MOUNTED WITH MAXIMUM 1/4" SHIM AND MAXIMUM 1X PT CONTINUOUS WOOD SPACER SECURED BY 1/4" ULTRACONS BY ELCO WITH 1 3/4" MIN. EMBEDMENT INTO GROUT FILLED MASONRY (JAMBS) OR INTO 3000 PSI CONCRETE. FOR INSTALLATION INTO METAL STRUCTURES USE 1/4-20 HWH GRADE 5 SDS (REFER TO ELEVATIONS FOR ANCHORS QTY. AND LAY-OUT) 1X BUCK TO BE PROPERLY DESIGNED BY OTHERS.	OPTION 3 FRAME MOUNTED DIRECTLY INTO 2X PT WOOD BUCK (SG>=0.55) W/ MAX. 1/4" SHIM AND SECURED BY #14 SS WOOD SCREWS OR 1/4" ULTRACONS WITH 1 3/8" MIN. EMBEDMENT. (REFER TO ELEVATIONS FOR ANCHORS QTY. AND LAY-OUT) 2X BUCK TO BE PROPERLY DESIGNED BY OTHERS.	OPTION 4 FRAME MOUNTED DIRECTLY INTO METAL STRUCTURES W/ MAX. 1/4" SHIM. 1/4"-20 PFH SDS GR 5 INTO MIN. 1/8" A36 STEEL OR 6063-T6 ALUMINUM. (REFER TO ELEVATIONS FOR ANCHORS QTY. AND LAY-OUT)

ALTERNATE ANCHORAGE LOCATION
ALL ABOVE OPTIONS CAN BE INSTALLED WITH ANCHORS LOCATED BELOW THE WEATHER STRIPPING AS SHOWN BELOW


QUALIFIED FRAME AND PANELS CONFIGURATIONS



RECTANGULAR XX
74X122




ARCHED XX
74X122



ELLIPTICAL XX
74X122




RECTANGULAR X
38X122




1/2 ARCHED X
38X122




1/2 ELLIPTICAL X
38X122




ELLIPTICAL X
38X122




ARCHED X
38X122






RECTANGULAR
PAIR O-XX-O -154X122
SINGLE O-X-O -118X122



ARCHED OR ELLIPTICAL O-XX-O
PAIR O-XX-O -154X122
SINGLE O-X-O -118X122




RECTANGULAR W/ TRANSOM
PAIR XX-O -74 1/2 X160 3/8
SINGLE X-O -38 3/8X160 3/8



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



ALTERNATE DOOR PANELS
NOTES:
1- THESE ARE JUST FOR A FEW VARIATIONS OF MANY POSSIBLE COMBINATIONS.
2- COMBINATIONS OF ALTERNATE DOOR PANELS ARE ACCEPTABLE IF GLASS DLO AREA AND DLO WOOD PANEL AREA NOT TO EXCEED THE SIZES LISTED ABOVE:

ENGINEER M. DE FIGUEIREDO
PE 52609
9715 W. BROWARD BLVD.
PLANTATION, FL 33324
PPMF@AOL.COM
ENGINEER SEAL
PEDRO DE FIGUEIREDO
PE 52609




PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220


SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
15 OF 16

DOOR SASH AND FRAME ASSEMBLY




SASH CONSTRUCTION:

THE TOP, BOTTOM AND INTERIOR RAILS WERE RABBET AND BUTT JOINED WITH A 5 X 0.70X2" LONG MORTISE AND (5" - 8 1/2") X 3/4 X (2"-2 7/8") LONG TENON TO THE HINGE AND LOCK STILES USING GLUE. THE ASTRAGAL FOR INACTIVE LEAF WAS FIRST NAILED USING 18GA X1 BRAD NAILS AND GLUE FURTHER SECURED TO THE LOCK STILE USING (9) #6X1 1/2 PFH SMS AT 13 1/2"OC IN THE FIELD. THE ASTRAGAL FOR ACTIVE LEAF WAS FIRST NAILED USING 18GA X1 BRAD NAILS AND GLUE FURTHER SECURED TO THE LOCK STILE USING (10) #8X2" PFH SMS AT 12"OC IN THE FIELD. A DECORATIVE MOLDING WAS ATTACHED AROUND THE INTERIOR GLAZING AREAS USING 18GA X1 BRAD NAILS. THE RECESSES WERE MADE TO ACCEPT WEATHER STRIP AS DESCRIBED LATER IN THE REPORT.



FRAME CONSTRUCTION:

THE JAMBS WERE RABBET AND BUTT JOINED WITH SILL AND HEADER USING (3) #10X3" PFH SMS IN EACH CORNER AND SEALED USING SILICONE. THE JAMBS, HEADER AND SILL HAD A NOTCH CUT-OUT TO ALLOW THE PLACEMENT OF THE WEATHERSTRIPPING. AN ALUMINUM BAR WAS ATTACHED TO THE SILL TOWARD THE EXTERIOR EDGE AS WEAR STRIP AND ATTACHED BY USING #6X1 1/4 SS PFH SMS AT 6 1/4" OC.



Pedro De Figueiredo
10/19/2023

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
PEDRO DE FIGUEIREDO ON THE DATE INDICATED HERE.



PRODUCT:
CUSTOM SERIES
OUTSWING DOORS
LARGE & SMALL MISSILE
IMPACT RATED

MANUFACTURER:
CUSTOM DOORS
222 NE 27TH STREET
MIAMI- FLORIDA- 33137
TEL: (561) 939-3368
FAX: (877) 839-2220

SCALE:
NA
DATE:
10/19/2023
DRAWING #
23-202
SHEET
16 OF 16